

ENERGY STORAGE Inspection



Supported by:



on the basis of a decision
by the German Bundestag

Research study
Energy Storage Inspection 2025

Authors
Dr.-Ing. Johannes Weniger
Nico Orth
Lucas Meissner

Research Group – Solar Storage Systems
HTW Berlin – University of Applied Sciences

Version
Version 1.0 (February 2025)

Web
solar.htw-berlin.de/inspection

Manufacturers who participated in the Energy Storage Inspection 2025

Energy efficiency benchmarking



and 5 anonymously participating companies



Energy management benchmarking



FENECON

KOSTAL



sonnen

and 2 anonymously participating companies


ENERGY STORAGE Inspection 2025

5 kW
class


The most efficient PV-battery systems 2025

10 kW
class

RCT POWER Power Storage DC 6.0
and Power Battery 7.6




1




RCT POWER Power Storage DC 10.0
and Power Battery 11.5

FRONIUS Primo GEN24 6.0 Plus
and **BYD** Battery-Box HVS 7.7




2




ENERGY DEPOT Centurio 10
and DOMUS 2.5

KOSTAL PLENTICORE plus G2 5.5
and **BYD** Battery-Box HVS 7.7



3




FRONIUS Symo GEN24 10.0 Plus
and **BYD** Battery-Box HVS 10.2

ENERGY STORAGE Inspection 2025

New participants with outstanding efficiency

SPI (10 kW)


A



FRONIUS Symo GEN24 12.0 Plus SC
and **BYD** Battery-Box HVS 12.8

95.2 %

A



KOSTAL PLENTICORE G3 M 10
and **BYD** Battery-Box HVS 12.8

95.1 %

A



FOX ESS H3-10.0-Smart
and ECS2900-H6

94.8 %

B



PV-battery system from an anonymously
participating manufacturer

94.0 %

B



PV-battery system from an anonymously
participating manufacturer

93.7 %


Outstanding: Rating of the energy efficiency with the System Performance Index SPI (10 kW) above 93.5 % (efficiency classes A and B).

All test results can be found here: solar.htw-berlin.de/inspection

htw

© solar.htw-berlin.de

Significant differences of the conversion efficiency during discharging








Conversion efficiency of two battery systems in discharge mode. Data: KIT

More information about the Energy Storage Inspection 2025: solar.htw-berlin.de/inspection

Large differences in efficiency between hybrid inverters

How efficient are the inverters if only 100 watts are consumed during the night?













 RCT POWER Power Storage DC 10.0	116 W	·	86 %
 FRONIUS Symo GEN24 12.0 Plus SC	132 W	·	76 %
 KOSTAL PLENTICORE G3 M 10	152 W	·	66 %
 GOODWE GW10K-ET-20	159 W	·	63 %
 Less efficient system with hybrid inverters	186 W	·	54 %


100 W


Note: The efficiency of hybrid inverters depends on the battery voltage, which varied between 195 V and 520 V depending on the system.
Data: AIT and KIT. All results from HTW Berlin and the Energy Storage Inspection 2025 can be found here: solar.htw-berlin.de/inspection

Home energy management systems of six manufacturers under study

Feature	Anonymous	Anonymous	 sonnen	 FENECON	 KOSTAL	 RCT power
 Implementation of online weather forecasts	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
 PV power forecast based on historical data	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
 Individual energy management settings ¹⁾	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
 Charging schedule is created locally or on the company server	server	local	server	local	local	local
 Updates of the charging schedule	10 min	n/s	1 h	1 s	1 h	30 min
 Optimized charging strategy to slow down ageing of the battery	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

¹⁾ with regard to the forecast-based charging strategy



Spending less time at a high state of charge extends battery lifetime

Charging strategy
of the battery

As soon as possible
(morning)

Forecast-based
(noon)

Forecast-based
(afternoon)



Dwell time
at SOC higher
than 90 %



99 h

72 h

43 h

 If a lithium-ion-battery spends less time fully charged, ageing effects slow down.

Data: Measurement of a 7-kWh-battery over 240 hours with different energy management strategies.

All results of the energy management test of KIT and HTW Berlin can be found in the Energy Storage Inspection 2025: solar.htw-berlin.de/inspection

Features of an outstanding PV-battery system energy management

Prosumers with PV systems should have a battery that...



delays charging in the morning on sunny days.



charges around noon to mitigate solar generation peaks.



reaches the fully charged state in the afternoon rather than early in the day.



minimizes dwell time spent at a high state of charge to reduce battery ageing.




updates its charging schedule regularly.







quickly responds to fluctuations in solar generation and residential load.



provides an accurate state of charge estimate to the energy management system.







Main topics of the Energy Storage Inspection 2025

1	Analysis of the German market for residential PV-battery systems	
2	Comparison of the system properties based on the test reports according to the Efficiency Guideline	
3	Simulation-based assessment of the PV-battery systems with the System Performance Index (SPI)	
4	Comparison of forecast-based energy management strategies of multiple PV-battery systems	



Main topics of the Energy Storage Inspection 2025

1	Analysis of the German market for residential PV-battery systems	
2	Comparison of the system properties based on the test reports according to the Efficiency Guideline	
3	Simulation-based assessment of the PV-battery systems with the System Performance Index (SPI)	
4	Comparison of forecast-based energy management strategies of multiple PV-battery systems	

Presence of climate friendly technologies in Germany



installed battery systems¹⁾

> 1.7 million




registered battery electric vehicles

> 1.8 million



installed heat pumps

> 2.0 million



residential pv systems²⁾

> 3.4 million




residential buildings in Germany

> 16.3 million




1) Battery systems with a capacity under 20 kWh. 2) PV systems with a nominal power between 2 kW and 20 kW.

Development of the PV-battery market in Germany




The residential PV market in Germany

PV market 2024: Significantly more small systems under 4 kW



Rated power of the PV-systems between 4 kW and 20 kW


Newly installed PV systems in Germany



© solar.htw-berlin.de


The residential battery system market in Germany

Residential battery markt 2024: Installations remain at a high level



Usable capacity of the battery systems between 4 kWh and 20 kWh

Newly installed battery systems in Germany



© solar.htw-berlin.de

System topologies of the PV-battery systems in Germany

Share of photovoltaic battery systems sold in Germany










image: AIT

Main topics of the Energy Storage Inspection 2025

1	Analysis of the German market for residential PV-battery systems	
2	Comparison of the system properties based on the test reports according to the Efficiency Guideline	
3	Simulation-based assessment of the PV-battery systems with the System Performance Index (SPI)	
4	Comparison of forecast-based energy management strategies of multiple PV-battery systems	


Participants of the Energy Storage Inspection 2025

- For the eighth consecutive year, all manufacturers of systems or components for solar electricity storage in residential buildings were invited to participate in the **Energy Storage Inspection 2025**.
- **17 manufacturers** took part in the Energy Storage Inspection 2025 with laboratory measurements from a total of **22 systems**.
- Two of those systems were purchased **independently**.
- Five manufacturers decided to **participate anonymously**.
- The following 12 manufacturers are contributing to **greater transparency** in the home storage market by participating by name.




Analysis of system properties according to the Efficiency Guideline

- Laboratory tests were conducted by **independent testing institutes** following the “**Efficiency Guideline for PV Storage Systems**”.
- To each analyzed system, a **system abbreviation** (e.g. A1) was assigned.
- The batteries of the **AC-coupled systems** A1 and C1 are equipped with battery inverters. The **DC-coupled systems** C2 to M1 have so-called hybrid inverters. System N1 is just a battery.
- Details about the **methodology** can be found in the Energy Storage Inspections 2018 and 2023.



Analyzed systems in the Energy Storage Inspection 2025


A1 ENERGY STORAGE Inspection 2025



VARTA pulse neo 6

Battery connection	AC
Battery Capacity	5.8 kWh
Discharge power	2.3 kW
PV output power	-
Efficiency class	B


B1 ENERGY STORAGE Inspection 2025



SAX Power Home Plus

Battery connection	AC
Battery Capacity	6.2 kWh
Discharge power	4.6 kW
PV output power	-
Efficiency class	B

C1 ENERGY STORAGE Inspection 2025




KOSTAL PLENTICORE BI G2 10/26 and
BYD Battery-Box Premium HVS 12.8

Battery connection	AC
Battery Capacity	12.0 kWh
Discharge power	10.1 kW
PV output power	-
Efficiency class	B

Analyzed systems in the Energy Storage Inspection 2025


C2 ENERGY STORAGE Inspection 2025



**KOSTAL PLENTICORE plus G2 5.5 and
BYD Battery-Box Premium HVS 7.7**

Battery connection	DC
Battery Capacity	7.1 kWh
Discharge power	3.8 kW
PV output power	5.5 kW
Efficiency class	B


C3 ENERGY STORAGE Inspection 2025



**KOSTAL PLENTICORE plus G2 10 and
BYD Battery-Box Premium HVS 12.8**

Battery connection	DC
Battery Capacity	11.9 kWh
Discharge power	6.3 kW
PV output power	10.0 kW
Efficiency class	A

C4 ENERGY STORAGE Inspection 2025




**KOSTAL PLENTICORE plus G2 10 and
DYNES Tower T14**

Battery connection	DC
Battery Capacity	13.5 kWh
Discharge power	4.8 kW
PV output power	10.0 kW
Efficiency class	B

Analyzed systems in the Energy Storage Inspection 2025


C5 ENERGY STORAGE Inspection 2025



KOSTAL PLENTICORE plus G2 10 and
PYLONTECH Force H2

Battery connection	DC
Battery Capacity	13.6 kWh
Discharge power	4.8 kW
PV output power	10.0 kW
Efficiency class	B


C6 ENERGY STORAGE Inspection 2025



KOSTAL PLENTICORE G3 M 10 and
BYD Battery-Box Premium HVS 12.8

Battery connection	DC
Battery Capacity	11.9 kWh
Discharge power	10.1 kW
PV output power	10.0 kW
Efficiency class	A

D1 ENERGY STORAGE Inspection 2025




FRONIUS Primo GEN24 6.0 Plus and
BYD Battery-Box Premium HVS 7.7

Battery connection	DC
Battery Capacity	7.4 kWh
Discharge power	5.8 kW
PV output power	6.1 kW
Efficiency class	A

Analyzed systems in the Energy Storage Inspection 2025


D2 ENERGY STORAGE Inspection 2025



**FRONIUS Symo GEN24 10.0 Plus and
BYD Battery-Box Premium HVS 10.2**

Battery connection	DC
Battery Capacity	9.9 kWh
Discharge power	8.9 kW
PV output power	10.2 kW
Efficiency class	A


D3 ENERGY STORAGE Inspection 2025



**FRONIUS Symo GEN24 12.0 Plus SC and
BYD Battery-Box Premium HVS 12.8**

Battery connection	DC
Battery Capacity	12.0 kWh
Discharge power	11.1 kW
PV output power	12.1 kW
Efficiency class	A

E1 ENERGY STORAGE Inspection 2025




**RCT POWER Power Storage DC 6.0 and
Power Battery 7.6**

Battery connection	DC
Battery Capacity	7.0 kWh
Discharge power	5.9 kW
PV output power	5.9 kW
Efficiency class	A

Analyzed systems in the Energy Storage Inspection 2025


E2 ENERGY STORAGE Inspection 2025



**RCT POWER Power Storage DC 10.0 and
Power Battery 11.5**

Battery connection	DC
Battery Capacity	10.6 kWh
Discharge power	9.9 kW
PV output power	10.0 kW
Efficiency class	A


F1 ENERGY STORAGE Inspection 2025



GOODWE GW10K-ET-20 and LX F16.0-H-20

Battery connection	DC
Battery Capacity	15.5 kWh
Discharge power	10.0 kW
PV output power	10.0 kW
Efficiency class	A

G1 ENERGY STORAGE Inspection 2025




ENERGY DEPOT Centurio 10 and DOMUS 2.5

Battery connection	DC
Battery Capacity	15.1 kWh
Discharge power	7.5 kW
PV output power	10.3 kW
Efficiency class	A

Analyzed systems in the Energy Storage Inspection 2025

H1 ENERGY STORAGE Inspection 2025



FOX ESS H3-10.0-Smart and ECS2900-H6

Battery connection	DC
Battery Capacity	16.0 kWh
Discharge power	9.8 kW
PV output power	9.9 kW
Efficiency class	A

I1 ENERGY STORAGE Inspection 2025



DC-coupled system of an anonymously participating manufacturer

Battery connection	DC
Battery Capacity	13.5 kWh
Discharge power	9.1 kW
PV output power	10.2 kW
Efficiency class	B

J1 ENERGY STORAGE Inspection 2025



DC-coupled system of an anonymously participating manufacturer

Battery connection	DC
Battery Capacity	10.3 kWh
Discharge power	10.0 kW
PV output power	9.9 kW
Efficiency class	B

Analyzed systems in the Energy Storage Inspection 2025

K1 ENERGY STORAGE Inspection 2025



DC-coupled system of an anonymously participating manufacturer

Battery connection	DC
Battery Capacity	14.2 kWh
Discharge power	8.9 kW
PV output power	10.2 kW
Efficiency class	D

L1 ENERGY STORAGE Inspection 2025



DC-coupled system purchased independently

Battery connection	DC
Battery Capacity	8.9 kWh
Discharge power	4.3 kW
PV output power	9.8 kW
Efficiency class	D

M1 ENERGY STORAGE Inspection 2025




DC-coupled system purchased independently

Battery connection	DC
Battery Capacity	9.8 kWh
Discharge power	4.8 kW
PV output power	10.0 kW
Efficiency class	G

Analyzed systems in the Energy Storage Inspection 2025

N1 ENERGY STORAGE Inspection 2025



MIBA VOLTHOME #03

(Battery storage without an inverter)

Battery connection	-
Battery Capacity	12.0 kWh
Discharge power (DC)	8.9 kW
PV output power	-
Efficiency class	-

System abbreviations


System	Product name
A1	VARTA pulse neo 6
B1	SAX Power Home Plus
C1	KOSTAL PLENTICORE BI G2 10/26 and BYD Battery-Box Premium HVS 12.8
C2	KOSTAL PLENTICORE plus G2 5.5 and BYD Battery-Box Premium HVS 7.7
C3	KOSTAL PLENTICORE plus G2 10 and BYD Battery-Box Premium HVS 12.8
C4	KOSTAL PLENTICORE plus G2 10 and DYNES Tower T14
C5	KOSTAL PLENTICORE plus G2 10 and PYLONTECH Force H2
C6	KOSTAL PLENTICORE G3 M 10 and BYD Battery-Box Premium HVS 12.8
D1	FRONIUS Primo GEN24 6.0 Plus and BYD Battery-Box Premium HVS 7.7
D2	FRONIUS Symo GEN24 10.0 Plus and BYD Battery-Box Premium HVS 10.2
D3	FRONIUS Symo GEN24 12.0 Plus SC and BYD Battery-Box Premium HVS 12.8

System abbreviations


System	Product name
E1	RCT POWER Power Storage DC 6.0 and Power Battery 7.6
E2	RCT POWER Power Storage DC 10.0 and Power Battery 11.5
F1	GOODWE GW10K-ET-20 and LX F16.0-H-20
G1	ENERGY DEPOT Centurio 10 and DOMUS 2.5
H1	FOX ESS H3-10.0-Smart and ECS2900-H6
I1	DC-coupled system of an anonymously participating manufacturer
J1	DC-coupled system of an anonymously participating manufacturer
K1	DC-coupled system of an anonymously participating manufacturer
L1	DC-coupled system purchased independently
M1	DC-coupled system purchased independently
N1	MIBA VOLTHOME #03

Nominal and usable battery capacity in comparison

- Permissible state of charge during normal operation
- Reserve to prevent deep discharge
- Reserve for ageing and safety



Usable battery capacity of the analyzed systems




© solar.htw-berlin.de


Systems E1, E2, I1 and N1: Due to a temperature-induced derating, the test could not be run at 100 % of the nominal power.

Comparison of data sheet specification and tested value

- For 15 of the 22 systems tested, **lower usable storage capacities** were determined in the laboratory test than those declared on the data sheets.
- A lower **depth of discharge (DOD)**, which protects the battery against deep discharge, is often the reason for the measured values being lower.
- The usable storage capacity of system B1 is **11 percentage points** below the value specified on the data sheet.




Nominal discharge power of the analyzed systems



© solar.htw-berlin.de



Average battery efficiency




© solar.htw-berlin.de

Systems E1, E2, I1 and N1: Due to a temperature-induced derating, the test could not be run at 100 % of the nominal power.


Energy conversion pathways of the different system topologies




Average conversion efficiency of AC battery discharging




Average efficiency of the energy conversion pathways



PV feed-in pathway efficiency




PV battery charging pathway efficiency




© solar.htw-berlin.de

AC battery charging pathway efficiency




© solar.htw-berlin.de

AC battery discharging pathway efficiency




© solar.htw-berlin.de

Comparison of data sheet specification and tested value



Newcomer: battery system with multi-level-technology




In order to be able to test the SAX Power Home Plus system at all, the KIT had to place a total of 24 DC measuring transformers between the electronics board and the 24 battery cell strings. In each battery cell string, 5 LFP battery cells with a capacity of 20 Ah are connected in series, resulting in a nominal voltage of 16 V per cell string (image: KIT).

Newcomer: battery system with multi-level-technology


- The system concept of the storage system Power Home Plus from SAX Power differs significantly from the system concepts of other manufacturers. The storage system is based on the so-called **multi-level-technology**.
- Five battery cells are connected in series to form a cell pack with a voltage of 16 V and are connected to a **separate power electronics unit**, which is known as an H-bridge.
- The cell packs are connected in series via the **H-bridge**.
- To achieve the necessary peak voltage of 325 V, **20 of the 24 cell packs** must be charged or discharged via the H-bridges.
- The individual cell packs are activated and deactivated with a time delay. This allows a **staircase-shaped sinusoidal** voltage curve to be generated at the output of the battery system

Typical load profile of residential households




© solar.htw-berlin.de


Partial load efficiencies of an inefficient hybrid inverter



Efficiencies of hybrid inverters at a household load of 100 watts




Partial load efficiencies of different hybrid inverters




© solar.htw-berlin.de



Dynamic control deviations of a slow battery system




Dynamic control deviations: dead and settling time




Stationary control deviations



Standby power consumption with discharged battery







Standby power consumption with fully charged battery




SPI

Main topics of the Energy Storage Inspection 2025

1	Analysis of the German market for residential PV-battery systems	
2	Comparison of the system properties based on the test reports according to the Efficiency Guideline	
3	Simulation-based assessment of the PV-battery systems with the System Performance Index (SPI)	
4	Comparison of forecast-based energy management strategies of multiple PV-battery systems	


Methodology of the simulation-based system evaluation

- **Simulation of the behavior** of the tested PV-battery systems over a year.
- The **System Performance Index (SPI)** is used to evaluate the systems based on the energy flows at the grid connection point. It considers the different economic values of the energy fed into the grid at 0.08 €/kWh and the energy supplied by the grid at 0.4 €/kWh.
- Parameterization of the simulation model „**PerMod**“ (version 2.2) based on the laboratory measurement results determined following the efficiency guideline.
- Including the sizing, conversion, control, and standby losses measured by the institutes.



System Performance Index SPI (5 kW) and SPI (10 kW)

1st reference case for the System Performance Index SPI (5 kW)




PV system
(5 kW)



Appliances
(5010 kWh/a)

2nd reference case for the System Performance Index SPI (10 kW)



PV system
(10 kW)



Appliances
(5010 kWh/a)



Heat pump
(2664 kWh/a)



Electric vehicle
(1690 kWh/a)

Please note: SPI (5 kW) and SPI (10 kW) are not comparable due to the different characteristics of the two reference cases.


Assignment of the systems to the reference cases

- Depending on the size of the **power electronics** and **battery storage**, the efficiency rating is conducted with the **SPI (5 kW)** or **SPI (10 kW)**.
- Only systems with a usable capacity below 8.0 kWh were rated with the **SPI (5 kW)**.
- For a rating with the **SPI (10 kW)**, a usable capacity below 16.0 kWh was required.
- The classification was based on the usable storage capacity determined in the **laboratory test**.
- 5 systems were rated with the SPI (5 kW), and 16 systems were assessed with the SPI (10 kW).




Systems rated with the System Performance Index (SPI)


- A1** VARTA pulse neo 6
- B1** SAX Power Home Plus
- C1** KOSTAL PLENTICORE BI G2 10/26 and BYD Battery-Box HVS 12.8
- C2** KOSTAL PLENTICORE plus G2 5.5 and BYD Battery-Box HVS 7.7
- C3** KOSTAL PLENTICORE plus G2 10 and BYD Battery-Box HVS 12.8
- C4** KOSTAL PLENTICORE plus G2 10 and DYNESS Tower T14
- C5** KOSTAL PLENTICORE plus G2 10 and PYLONTECH Force H2
- C6** KOSTAL PLENTICORE G3 M 10 and BYD Battery-Box HVS 12.8
- D1** FRONIUS Primo GEN24 6.0 Plus and BYD Battery-Box HVS 7.7
- D2** FRONIUS Symo GEN24 10.0 Plus and BYD Battery-Box HVS 10.2
- D3** FRONIUS Symo GEN24 12.0 Plus SC and BYD Battery-Box HVS 12.8
- E1** RCT POWER Power Storage DC 6.0 and Power Battery 7.6
- E2** RCT POWER Power Storage DC 10.0 and Power Battery 11.5
- F1** GOODWE GW10K-ET-20 and LX F16.0-H-20
- G1** ENERGY DEPOT Centurio 10 and DOMUS 2.5
- H1** FOX ESS H3-10.0-Smart and ECS2900-H6



Low efficiency reduces energy fed in and increases grid consumption




Example for determining the System Performance Index (SPI)




Grid feed-in revenues and grid purchase costs as well as cost savings achieved when using the ideal (loss-free) and real example system K1 (feed-in tariff 0.08 €/kWh, grid purchase price 0.4 €/kWh). Framework conditions according to the 2nd reference case.

Loss analysis of the systems assessed with the SPI (5 kW)



© solar.htw-berlin.de

Loss analysis of the systems assessed with the SPI (10 kW)




© solar.htw-berlin.de

Definition of the efficiency classes for PV-battery systems


- Due to the different SPI values, the threshold values for reaching the individual **efficiency classes** vary.

Class	Rating	SPI (5 kW)	SPI (10 kW)
A	very good	$\geq 92.5 \%$	$\geq 94.5 \%$
B	very good	$\geq 90.5 \%$	$\geq 93.5 \%$
C	good	$\geq 88.5 \%$	$\geq 92.5 \%$
D	good	$\geq 86.5 \%$	$\geq 91.5 \%$
E	in need of improvement	$\geq 84.5 \%$	$\geq 90.5 \%$
F	in need of improvement	$\geq 82.5 \%$	$\geq 89.5 \%$
G	inadequate	$< 82.5 \%$	$< 89.5 \%$

SPI (5 kW) and efficiency classes of the analyzed systems




Influence of different losses on the SPI (5 kW)




© solar.htw-berlin.de

SPI (10 kW) and efficiency classes of the analyzed systems



Influence of different losses on the SPI (10 kW)

Less efficient system with DC coupled battery storage



© solar.htw-berlin.de

Why is a high system efficiency important?

- Efficiency losses reduce the **potential savings** of a PV-battery system. The economic losses for the systems evaluated with the SPI (10 kW) lay between 94 €/a and 276 €/a.
- Households that choose a highly efficient PV-battery system can save up to an additional **1820 € within the first ten years** of operation compared to a less efficient system.



Summary of the results of the system evaluation

- The Energy Storage Inspection 2025 analyzed and compared the energy efficiency of **21 battery systems**.
- In the reference case up to 5 kW, a DC-coupled system from RCT Power came out on top with an **SPI (5 kW) of 92.6 %**.
- It was closely followed by the hybrid inverters FRONIUS Primo GEN24 6.0 Plus and KOSTAL PLENTICORE plus G2 5.5, both of which competed in combination with the BYD Battery-Box Premium HVS 7.7.
- The system Power Storage DC 10.0 and Power Battery 11.5 from RCT Power achieved the highest **SPI (10 kW)** with a value of **96.4 %**.
- 18 of the 21 systems tested scored with a **very good system efficiency** and achieved either the efficiency classes A or B.
- However, the range of system efficiency is still very wide – the least efficient system only achieved the **efficiency class G**.



Supported by:



on the basis of a decision
by the German Bundestag

solar.htw-berlin.de/inspection